

Amendment to Resolution 209 (Planning Commission's
recommendations)
KEY FOR COMPREHENSIVE WATER AND SEWER PLAN AMENDMENTS

This KEY explains the proposed amendments to Resolution 209, to amend the Resolution according to the recommendations of the Planning Commission. The green text indicates the Planning Commission's proposed amendments.

KEY

Boldface..... Heading or defined term.
Underlining..... Added to existing law by original bill.
~~Strikethrough~~..... Deleted from existing law by original bill.
Double underlining..... Added to bill by amendment.
~~Double strikethrough~~ Deleted from bill by amendment.
* * * Existing law unaffected.

In re-comparing the text of these amendments with the original text of the Comprehensive Water and Sewer Plan (CWSP), staff became aware that the former draft amendments had deleted text or charts from the original CWSP text and that those deletions had not been identified by strikethrough in the amendments.

Although those deletions were/are not germane to the allocation of 40,500 GPD to Martingham, they have been included in this draft and shown in strikethrough for purposes of accuracy and completeness.

Staff is available to answer any questions or provide any additional information you might require regarding this or any other matter.

There are three (3) proposals:

(1) Resolution 209 as originally proposed which takes the 40,500 GPD allocation from the Town of St. Michaels;

(2) Resolution 209 as proposed for amendment by the Planning Commission, Which Takes the 40,500 GPD allocation from the Town of St. Michaels and separately establishes a reserve account by taking the 40,500 GPD from Royal Oak, Newcomb & Bellevue Sewer Service Area; and,

(3) Resolution 210, to take the 40,500 GPD allocation from Royal Oak, Newcomb & Bellevue Sewer Service Area.

TALBOT COUNTY COMPREHENSIVE WATER AND SEWER PLAN – October 2002

TALBOT COUNTY REGION II - SANITARY DISTRICT ALLOCATION PROGRAM

Background

The 2002 Report of the Review for the Talbot County Comprehensive Water and Sewerage Plan incorporated a detailed analysis to support the planning, design and construction of a 1.0 million gallon per day (MGD) wastewater treatment plant to replace the existing Region II Wastewater Treatment Plant with a design capacity of 500,000 gallon per day. Through negotiations with the Maryland Departments of the Environment (MDE) and Planning (MDP), the County and the State agreed that the 1.0 million gallon per day (MGD) facility should be constructed, but the National Pollution Discharge Elimination System (NPDES) Permit would only allow the discharge of 800,000 gallons per day (gpd). The proposed wastewater treatment plant would be capable of ~~biological~~enhanced nutrient removal, and would be capable of discharging concentrations of 3.0 mg/l of total nitrogen and 0.3 mg/l of total phosphorus at temperature of 10°C or greater to the receiving stream, Miles River.

After seeking approval from MDE and MDP as to the design capacity of the Region II Wastewater Treatment Plant, Talbot County sought engineering proposals for design services for the new 1.0 MGD ~~Biological~~Enhanced Nutrient Removal (~~BNREN~~) Upgrade and Expansion of the Region II Wastewater Treatment Plant. The County selected Rummel, Klepper and Kahl (RK&K) through a competitive bidding process to design the new ~~BNREN~~ Wastewater Treatment Plant.

During the design process, the County and RK&K sought ways to maximize the operation of the new 1.0 MGD ~~BNREN~~ Upgrade and Expansion of the Region II Wastewater Treatment Plant. To provide temporary storage of extraneous flows experienced during periods of wet weather, the Bardneph process would be constructed with two trains, each train capable of treating 500,000 gpd. In addition to the two train process, a flow equalization basin was incorporated into the new wastewater treatment plant with a capacity of 100,000 gallons. The flow equalization basin would be connected to one of the treatment trains providing the County with 600,000 gallons of storage of extraneous flow in addition to the 1.7 million gallon pond used for emergency storage and volume for shellfish protection as required within the NPDES Permit.

During the initial operation of the new Region II Wastewater Treatment Plant, flows would be treated through one train while efforts during this period would be made to improve the sewer collection system. As improvements were being made to the sewer collection system, thus creating capacity at the Region II Wastewater Treatment Plant, new opportunities to extend sewer into areas served by onsite sewage disposal systems would be created. Based on the information provided in the 1992 Update of the Talbot County Comprehensive Water and Sewerage Plan, the soils west of Route 50 are poor draining, clay laden soils, thus requiring groundwater penetration for effluent disposal for onsite sewage disposal systems. Utilizing the restricted, denied access sewer service policy that was adopted for the villages of Unionville, Tunis Mills and Copperville, the County could utilize the capacity reserved for inflow and infiltration for addressing water quality problems associated with septic systems thus establishing a program for protecting the tributaries of the Chesapeake Bay and promoting improvements of water quality of the tributaries in Talbot County.

As the design of the 1.0 MGD facility was being completed, MDE requested that the County execute the ENR agreement to proceed with the funding of the project using ~~BNR~~ENR grant funds and State Revolving Funds for low-interest loans. The ENR agreement was forwarded to the County Council President for execution, however, due to public concern as to the design and construction of a 1.0 MGD wastewater treatment facility to be permitted for 0.8 MGD, the County Council sought information from the Department of Public Works and input from the general public. During this period, the Region II Wastewater Treatment System experienced problems with extraneous flows associated with groundwater and stormwater entering the sewer collection system.

These extraneous flows are defined as inflow and infiltration (I&I) flows. As the County was attempting to complete the design of the ~~BNR~~ENR upgrade and expansion of the Region II Wastewater Treatment Plant, the County was also completing in-pipe flow monitoring and smoke testing of the gravity sewer collection system in the Town of St. Michaels and the communities of Rio Vista and Bentley Hay. Through analysis by the Department of Public Works, the amount of I&I flows entering the Region II Wastewater Treatment Plant was fairly consistent with the difference in the daily average flows recorded for calendar year 2002 and 2003. In 2002, the Mid-Atlantic Region of the United States experienced a serious drought and flows at the Region II Wastewater Treatment Plant averaged 298,000 gpd. In 2003, the Eastern Shore and the State of Maryland experienced record snowfalls and rainfalls that resulted in a yearly daily average flow of 486,000 gpd being recorded at the Region II Wastewater Treatment Plant. Using the difference in the yearly daily average flows for calendar year 2002 and 2003, the estimated amount of I&I entering the Region II Wastewater Treatment Plant is 170,000 gpd.

Revised Design Capacity from 1.0 MGD to 0.660 MGD

As concerns from the general public mounted concerning the 1.0 MGD plant, permitted for 0.8 MGD and on-going problems with the sewer collection system, the County Council introduced and adopted Resolution 106 to authorize the design and construction of a ~~BNR~~ENR wastewater treatment plant with a design capacity of 0.660 MGD.

With the adoption of Resolution 106, a conflict resulted within the Talbot County Comprehensive Water and Sewerage Plan associated with the analysis in Chapter 2 supporting the design and construction of a 1.0 MGD facility to be permitted for 0.8 MGD and the decision of the County Council to design and construct a 0.660 MGD ~~BNR~~ENR Wastewater Treatment Plant. Because of this conflict, MDE and MDP requested that Talbot County complete a new analysis to determine the allocation of capacity of the Region II Wastewater Treatment Plant to the various areas served by the treatment facility. ~~The analysis~~In 2004, DPW completed ~~herein utilized existing data the analysis and various assumptions~~worked with the County Council to ~~determine existing and future flows from the various~~adopt the revised sewer ~~service areas~~ ~~to allocations~~for the Region II Wastewater Treatment Plant having a designed hydraulic capacity of 660,000 gpd.

Determination of Wastewater Flow from the Villages, Communities, and Other Areas

In the 2002 Report of the Review, the analysis used principles ~~effrom the~~ MDE guidelines for determining water generation from a residential structure with the assumption that the wastewater generation equaled the water generation. Typically wastewater generation is a percentage of water generation due to water being used for lawns, to wash cars or fill pools thus resulting in water being used but is not being discharged into the sewer system. In accordance with the MDE guidelines, flow projections for wastewater less than 80 gallons per day (gpd) per person must be justified. Metering the wastewater flow for over 17 months and reviewing the data, the metered data is consistent and provides justification for using a flow projection less than 80 ~~gallons per day per person or 184 gallons per equivalent dwelling per day~~ gpd per person or 184 gallons per equivalent dwelling per day. For areas within the Town of St. Michaels that are served by a gravity sewer system, the allocation of wastewater flow per dwelling shall be 250 gpd per dwelling. This flow rate uses a population equivalent of 2.3 people per dwelling with an estimated wastewater generation of 80 gpd per person which totals 184 gpd per dwelling. To help account for inflow and infiltration 66 gpd is added to the flow rate calculated for the dwelling to establish a flow rate of 250 gpd per dwelling (184 gpd/dwelling + 66 gpd of I&I/dwelling).

In an attempt to accurately assess the wastewater generation for the villages of Unionville, Tunis Mills, Copperville, Royal Oak, Newcomb, and Bellevue, the wastewater flows were metered at the Unionville Pump Station serving the villages of Unionville, Tunis Mills and Copperville and Royal Oak Pump Station. The Royal Oak Pump station receives wastewater flows from the villages of Bellevue, Newcomb and Royal Oak as well as the flows from the Unionville Pump Station. The recorded flows from January, 2003 through May, 2004 are listed in Table 1.

Table 1 - Pump Station Flow Data

MONTH	Royal Oak Pump Station No. 1 (gallons per day)	Unionville Pump Station Unionville, Tunis Mills and Copperville Flows (gallons per day)	Royal Oak, Newcomb, and Bellevue Flows (gallons per day)
January, 2003	64,000	22,000	42,000
February, 2003	80,000	28,000	52,000
March, 2003	77,000	25,000	52,000
April, 2003	65,000	20,000	45,000
May, 2003	68,000	20,000	48,000
June, 2003	74,000	22,000	52,000
July, 2003	66,000	19,000	47,000
August, 2003	67,000	20,000	47,000
September, 2003	74,000	20,000	54,000
October, 2003	68,000	19,000	49,000
November, 2003	71,000	23,000	48,000
December, 2003	68,000	22,000	46,000
January, 2004	61,000	21,000	40,000
February, 2004	65,000	20,000	45,000
March, 2004	64,000	17,000	47,000
April, 2004	68,000	20,000	48,000

May, 2004	56,000	20,000	36,000
-----------	--------	--------	--------

Using the data provided in Table 1, the daily average flows were calculated as follows:

Unionville, Tunis Mills and Copperville

Calendar Year 2003 Daily Average Flow:	21,700 gallons per day
Calendar Year 2004 Daily Average Flow:	19,600 gallons per day
2003/2004 (Jan – May) Daily Average Flow:	21,100 gallons per day

Royal Oak, Newcomb and Bellevue

Calendar Year 2003 Daily Average Flow:	48,400 gallons per day
Calendar Year 2004 Daily Average Flow:	43,800 gallons per day
2003/2004 (Jan – May) Daily Average Flow:	47,100 gallons per day

Unionville, Tunis Mills and Copperville

Within the Region I - Unionville, Tunis Mills and Copperville Sewer Service Area, 175 residential structures, as reported in 2004, are connected to the sewer system with a daily average flow of 21,100 gpd, reported for from January 2003 to May 2004. Based on Fiscal Year (FY) 2011, 170 residential structures were being billed for sewer service, but the past 17 months 2004 analysis will be used since the five (5) residential structures still exist but are not occupied. Approximately 48 lots can be connected in the future. To assess the future flows from the proposed 48 lots, the daily average flow of 21,100 gpd was divided by the existing number of residential structures connected to the sewer system to establish a flow per connection. The flow per connections was calculated to be 121 gpd per connection. To calculate the future flow rate of 48 lots, or future connections, 48 lots were multiplied by 121 gpd per connection, with the future flow being estimated to be 5,900 gpd. Because of various unknowns such as missing and/or broken cleanout caps, broken laterals, leaking tank seals and/or leaking tank lids, a safety factor was used. Consistent with EPA and MDE guidelines, a safety factor of 20% was used to estimate the flow allocation for this region, and this safety factor addresses the variability of wastewater flows for small systems. The following outlines how the flow allocation for Region I Unionville, Tunis Mills and Copperville Sewer Service Area, of 32,400 gpd, was determined.

Estimated Total Flow (Q) = Existing Flow (Q _{existing}) + Future Flows (Q _{future}) + 20% Safety Factor
32,400 gpd = 21,100 gpd + 5,900 gpd + 5,400 gpd

Royal Oak, Newcomb and Bellevue

Within the Region II - Royal Oak, Newcomb and Bellevue Sewer Service Area, 376 residential structures, as reported in 2004, are connected to the sewer system with a daily average flow of 47,100 gpd as recorded for the past 17 months. Approximately 460 139 lots can be connected in the future. To assess the future flows from the proposed 460 139 lots, the daily average flow of 47,100 gpd was divided by the existing number of residential structures connected to the sewer system to establish a flow per connection. The flow per connection was calculated to be 126 gpd per connection. To calculate the future flow rate of 460 139 lots, or future connections, 460 139 lots were multiplied by 126 gpd per connection, with the future flow being estimated to be

~~58,000~~ 17,500 gpd. – Because of various unknowns such as missing and/or broken cleanout caps, broken laterals, leaking tank seals and/or leaking tank lids, a safety factor was used. Consistent with EPA and MDE guidelines, a safety factor of 20% was used to estimate the flow allocation for this region, and this safety factor addresses the variability of wastewater flows for small systems. The following outlines how the flow allocation for the Region II Royal Oak, Newcomb and Bellevue Sewer Service Area, of ~~126,200~~ 77,600 gpd, was determined.

Estimated Total Flow (Q) = Existing Flow (Q_{existing}) + Future Flows (Q_{future}) + 20% Safety Factor
~~126,200~~ 77,600 gpd = 47,100 gpd + ~~58,000~~ 17,500 gpd +
~~21,100~~ 13,000 gpd

Community of Bentley Hay

In completing the 2002 Report of the Review of the Talbot County Comprehensive Water and Sewerage Plan, the Department of Public Works learned that the subdivision of Bentley Hay was excluded from the County and State Priority Funding Area maps. The subdivision of Bentley Hay is outside the municipal boundary of the Town of St. Michaels, yet receives water service from the Town of St. Michaels, and receives sewer service from Talbot County via the Region II Wastewater Treatment Plant.

The Subdivision of Bentley Hay dates back to 1947 and has been assumed to be built out as of this date. The projected sanitary sewer flow from this subdivision was estimated to be 29,800 gallons per day that was reported in the Region II Wastewater Treatment Plant Allocation Program in the 2002 Report of the Review.

The allocation as presented in the 2002 Report of the Review shall be the same within the revised allocation. The Bentley Hay community allocation shall be 29,800 gpd.

Other County Areas

As presented in the 2002 Report of the Review, flows from various areas in the County were incorporated into the allocation program. These areas included Chester Park, areas outside the priority funding areas and properties within the priority funding areas identified by ~~MDP~~ the Maryland Department of Planning (MDP). In addition to the areas in the County, estimated flows from the Perry Cabin Inn were incorporated into the flow calculations.

With the completion of the expansion of the Inn at Perry Cabin, the estimated flow of 8,000 gpd has been assumed to be part of the existing flows for the Town of St. Michaels and Rio Vista. With the reduced capacity of the Region II Wastewater Treatment Plant, estimated wastewater flows from the Community of Back Creek and Chester Park have been incorporated into the category of Other County Areas with an estimated existing flow of 3,000 gpd and 12,000 gpd for future flows. The areas allocated wastewater flow in the 2002 Report of the Review, Unincorporated Areas being identified by MDP as being priority funding areas shall be incorporated into the future flows and made part of the reserved capacity for I&I flows for the Town of St. Michaels and Rio Vista as presented in this analysis. Both the County and the Town

of St. Michaels will have to determine how future areas will be served with the capacity identified for future flows and the flows associated with the reserved capacity to I&I flows.

Town of St. Michaels and Rio Vista

~~As presented in the 2002 Report of the Review, the estimated existing and future flows from the incorporated limits of the Town and the Rio Vista Subdivision was 544,000 gpd. These wastewater flows were estimated on the statutory criteria for a priority funding areas (PFAs), minimum density of 3.5 lots per acre. In calculating this estimated flow rate, the County used data collected by Hyder Consulting that was presented in their August 2000 Region II Wastewater Collection System Study. The estimated flow rate for growth and high priority areas within the corporate limits of the Town was reported as 176,000 gpd that was incorporated into the total estimated sewerage flow of 544,000 gpd.~~

~~The original design of the Region II Wastewater Treatment Plant was to serve primarily the Town of St. Michaels. The estimated flow associated with the unincorporated areas around St. Michaels and within the MDP defined priority funding area was found to be approximately 52,500 gpd. This includes Chester Park and the proposed expansion at the Inn at Perry Cabin. The estimated flows of 42,000 gpd, excluding Chester Park and the Inn at Perry Cabin, will need to be established at the wastewater treatment plant by expanding the plant capacity or by making corrections within the St. Michaels sewer collection system to reduce the amount of flow being associated with extraneous, I&I flows.~~

Within this analysis, the existing flows for St. Michaels and Rio Vista were determined by deducting the recorded and estimated flows for other areas and the extraneous flows associated with I&I flows. The estimated existing flow of 197,000 gallons per day was determined for St. Michaels and Rio Vista. To estimate the future flows from the Town of St. Michaels and Rio Vista, I&I flows were held constant establishing a reserved capacity for existing and future extraneous flows. The safety factors for Unionville, Tunis Mills and Copperville and Royal Oak, Newcomb and Bellevue Sewer Service Areas were incorporated as part of extraneous flows held constant as reserved capacity.

In 2004, the estimated future flows for the Town of St. Michaels and Rio Vista was estimated to be 116,100 gpd, or 109,700 gpd for the Town of St. Michaels and 6,400 gpd for Rio Vista. In about the past five years, two large developments which were included in the future flows for the Town of St. Michaels have been reduced from 400 lots to one with the other being reduced from 250 lots to 16 proposed lots. Based on this reduction of future lots, the future flows for the Town of St. Michaels has been reduced from 109,700 gpd to 69,200 gpd. The Department of Public Works will continue to work with the Town of St. Michaels in adjusting the future flow allocation to maintain consistency of the Talbot County Comprehensive Water and Sewerage Plan with the Town of St. Michaels Comprehensive Plan.

Community of Rio Vista

After completing the analysis to determine the existing and future flows for St. Michaels and Rio Vista, an estimate of the wastewater flows being generated by Rio Vista was completed. The

Rio Vista Community has 264 residential lots with a church owning 16 of these lots. Incorporated into the Rio Vista flows are the lots along Maryland Route 33 with approximately 65.25 equivalent dwelling units (EDUs) with a future total 97.25 EDUs. Using 200 gallons per day per residential lot, the estimated wastewater flow for Rio Vista area was determined to be 63,050 gallons per day with 49,600 gpd associated with 248 residential lots in the Rio Vista Community, 400 gallons per day of wastewater flow being estimated for the church, and 13,050 gpd being allocated for the businesses on Maryland Route 33. The future flows for this area were estimated to be 6,400 gpd with the assumption that Rio Vista was built-out, thus establishing a total allocation of ~~67~~69,450 gpd for this area.

Inflow and Infiltration Flows and Reserved Capacity

Using calendar year 2003 flow data for the Region II Wastewater Treatment Plant and the design capacity of 500,000 gpd, the allocations for the various sewer service areas are provided in Table 2. Based on the amount of extraneous, I&I flows experienced in calendar year 2003 being 170,000 gpd, this value has been shown in Table 2 as I&I flows. Because of the extraneous flows currently being recorded at the Region II Wastewater Treatment Plant, measures need to be taken to reserve this capacity to avoid over allocating the existing and future capacity of the plant.

The estimated flow being reserved for I&I is 170,000 gpd. The 170,000 gpd is primarily associated with the extraneous flows experienced in the gravity sewer collection system within Town of St. Michaels and the communities of Bentley Hay and Rio Vista but impacts the overall capacity of the Region II Wastewater Treatment Plant. By reserving capacity for the extraneous, I&I flows, this capacity will buffer peak flows associated with future extraneous, I&I flows allowing the Region II Wastewater Treatment Plant to be operated within the permit limitations for capacity. As improvements to the gravity sewer system are completed, the flows recorded at the Region II Wastewater Treatment Plant, recorded through in-pipe flow monitoring and computer analysis can be used to determine how much capacity can be removed from the reserved capacity set aside for I&I flows.

The 170,000 gpd allocated for I&I flows (or the wastewater treatment plant safety factor) equates to approximately 26% of the design capacity. The use of a 20% safety factor for the village flows is associated with variability of small flows and was not intended to reflect additional reserve capacity within the wastewater treatment plant. As future efforts are made to reduce extraneous flows entering the St. Michaels Gravity Sewer Collection System, capacity within the Region II Wastewater Treatment Plant can be reallocated from the reserve and used to address sewer needs and water quality improvements.

Table 2– Existing Wastewater Flows to the Region II Treatment Plant

SEWER SERVICE AREA	EXISTING FLOWS
Existing Design Capacity	500000
Recorded Flows for Calendar Year 2003	-468000
Remaining Capacity	32000
REVIEW OF EXISTING FLOWS	
Total for the Region II Wastewater Treatment Plant	468000
Bentley Hay	-29800
Unionville, Tunis Mills and Copperville	-21100
Royal Oak, Newcomb and Bellevue	-47100
Other County Areas	-3000
Inflow and Infiltration Flow	-170000
St. Michaels And Rio Vista	197000

As presented in Table 2, the existing flows for the Town of St. Michaels and Rio Vista equates to 197,000 gpd with 133,950 gpd being estimated for the Town of St. Michaels and 63,050 gpd being estimated for the Rio Vista area. ~~Using the flows presented earlier in the analysis, the projected flows for new wastewater treatment plant with a capacity of 660,000 gpd has been presented in Table 3.~~

Table 3. Allocation of Capacity at the Region II Wastewater Treatment Plant

SEWER SERVICE AREA	EXISTING FLOWS	FUTURE FLOWS	RESERVED CAPACITY FOR I&I	TOTAL FLOWS
St. Michaels	133950	109700	143500	387150
Rio Vista Area	63050	6400	0	69450
Bentley Hay	29800	0	0	29800
Unionville, Tunis Mills and Copperville	21100	5900	5400	32400
Royal Oak, Newcomb and Bellevue	47100	58000	21100	126200
Other County Areas	3000	12000	0	15000
Inflow and Infiltration Reserved Capacity	170000	0	0	0
Totals	468000	192000	170000	660000

~~In comparison with the 2002 Report of the Review, the existing and future flows for the Town of St. Michaels and the Rio Vista were reduced from 544,000 gpd to 313,100 gpd. The wastewater flow allocation for the Town of St. Michaels can be increased as sewer collection system improvements are made and confirmed by the Department of Public Works to have actually reduced the amount of I&I flow into the sewer collection system.~~

Community of Martingham and Harbourtowne Golf Resort and Conference Center

In April, 2004, representatives from Martingham Utilities Cooperative met with the Talbot County Department of Public Works to discuss the possibility of connecting to the Region II Wastewater Treatment Plant. The current ~~operation of the~~ wastewater treatment system serving the residents of the Martingham Community and the Harbourtowne Golf Resort and Conference Center ~~is~~ consists of a two-stage stabilization lagoon followed by disinfection and an effluent

holding pond. Under proper weather conditions, the treated effluent is spray irrigated on various fairways ~~with one spray irrigation site being on private land where Martingham Utilities paid for an easement to spray irrigate on the land.~~

The wastewater treatment facility for the Martingham Community has a treatment plant capacity of 75,000 ~~gallons per day gpd~~ but the spray disposal areas ~~have had~~ a permit limit of 66,800 ~~gallons per day gpd~~. The Martingham Community serves ~~320~~330 residents and a commercial establishment, the Harbortowne Golf Resort and Conference Center.

Based on information received back in 2004 from Martingham Utilities Cooperative, MDE, and Maryland Environmental Service, the contract-operator for the ~~Region II and~~ Martingham Wastewater Treatment ~~Plants~~Plant at the time, the spray irrigation site on private land ~~has had~~ been reduce by nearly 65% of the usable land area due to MDE requiring a 200 foot setback. ~~Based on a meeting with MDE, It was concluded that~~ the only option available to Martingham Utilities ~~is was~~ to send flow to the Region II Wastewater Treatment Plant, especially during periods of dry weather in the late fall and winter months to establish enough pond capacity to retain water in the ponds when Martingham ~~Utilities cannot~~ spray irrigate.

Based on the discussions with Martingham Utilities Cooperative back in 2004, up to 8,000,000 gallons of either raw wastewater or treated effluent would need to be sent to the Region II Wastewater Treatment Plant. During years with normal precipitation amounts, an estimated 2,000,000 to 4,000,000 gallons of flow would be sent to the Region II Wastewater Treatment. In the event of an extremely wet year, 8,000,000 gallons would be sent to the Region II Wastewater Treatment Plant over a period of 300 days (26,667 gpd).

For the County to participate with Martingham Utilities Cooperative and MDE in resolving this issue, corrective measures that involve the Region II Wastewater Treatment Plant and Sewer Collection System ~~will need~~needed to be completed in two phases. First, a short-term strategy would employ a temporary force main laid within the road drainage ditches or other approved temporary strategy conveying treated effluent to the Region II Wastewater Treatment Plant. The standard operating procedure, in the short-term, would need to limit the amount of treated effluent to 19,000 gpd or less on a calendar year daily average flow with no flow being conveyed during periods of rainfall. During this short-term, temporary period, improvements to the sewer collection system ~~must would~~ occur, and the County ~~believes~~believed that ~~these~~ improvements ~~would need to be made~~the sewer lines in areas around Mill and Carpenter Streets, and the north end of Town ~~to would~~ reduce enough I&I flows from the system to allow Martingham to connect to the Region II Sewer Collection System on a permanent basis.

~~Assuming~~In 2008, the Talbot County Sanitary District assumed ownership of the Martingham Wastewater Treatment System. After assuming ownership of this wastewater system, the County pursued a long-term strategy is approved with of constructing a new force main being constructed from the Martingham Wastewater Treatment Plant to the sewer collection system of the Region II Wastewater Treatment Plant, ownership of the Martingham plant would need to be considered by. To complete this long-term strategy, the Talbot County Sanitary District. ~~This would allow the County applied for low-interest loans and a grant through the USDA Rural Utility Service program in 2010. Due to limited grant funds being offered to control the means~~

~~of treating the wastewater and operating the spray irrigation system to comply with the two discharge permits, the Region II Wastewater Treatment Plant NPDES and extend the sewer to the Martingham NPDES permits~~Community. Talbot County submitted a grant request to the Maryland Water Quality Infrastructure Financing Program administered by MDE in 2012 seeking up to \$2.0 million in grant funds or loan forgiveness.

Because of the low-strength of the raw wastewater being treated at the Region II Wastewater Treatment, raw sewage from the Martingham Wastewater Treatment Plant should be pumped for treatment at the Region II Wastewater Treatment Facility ~~using the same flow restriction outlined earlier for total, average gallons treated in a calendar year. The Region II Wastewater Treatment Facility would handle up to 26,700 gpd of raw sewage during wet years such as 2003.~~ In reviewing the metered flows at the Martingham Wastewater System, an average flow per EDU was determined to be 122.5 gpd/EDU. As previously mentioned, the Martingham Community consists of 330 EDUs which consists of residential structures and the Harbortowne Golf Resort and Conference Center, thus 40,500 gpd will be allocated from the future flows for the Town of St. Michaels.

~~In developing capacity at the Region II Wastewater Treatment Plant, improvements with the sewer collection system must be implemented and completed. These improvements would take place in the various sections of the sewer collection system found to have the highest priority for being repaired. The allocation for Martingham has been allocated from the flows designated within the reserved capacity for I&I flows. The revised flow allocation for the existing Region II Wastewater Treatment Plant with a design capacity of 500,000 has been presented in Table 4. Table 5 lists the flows allocations associated with the new treatment facility with a design capacity of 660,000 gallons per day after making improvements in the collection system and establishing a permanent solution to the problem. The Board for Martingham Utilities Cooperative and the Talbot County Department of Public Works shall continue to review and explore options to establish a permanent solution to addressing the discharge permit and report to the County Council the various solutions prior to committing capacity of the 660,000 gallon per day Wastewater Treatment Plant.~~

~~Table 4. Revised Allocation~~The revised flow allocation for the existing flows to the Region II Wastewater Treatment Plant with a design capacity of 660,000 gpd has been presented in Table 4. In developing the existing flows, the reported flows are estimates which will fluctuate due to various factors with the most influential factor being wet weather. To avoid an over-allocation of wastewater treatment capacity, 170,000 gpd, as reported in the 2002 Report of the Review and the revised Talbot County – Region II Sanitary District Allocation Program dated August 11, 2004, has been used to reserve capacity during wet weather events. The Department of Public Works continues to complete improvements within the sewer collection system, but there is very little data to accurately estimate a reduction in estimated I&I allocated flows.

Table 3. Review of Allocation of Capacity for ~~500~~Existing Flows with 170,000 ~~gallons-per day~~gpd of I&I

SEWER SERVICE AREA	EXISTING FLOWS
St. Michaels And and Rio Vista	197000
Bentley Hay	29800

TALBOT COUNTY COMPREHENSIVE WATER AND SEWER PLAN – October 2002

Unionville, Tunis Mills and Copperville	21100
Royal Oak, Newcomb and Bellevue	47100
Other County Areas	3000
Martingham Community	19,000 40500
<u>Subtotal Existing Flows – Estimated</u>	338500
<i>Inflow and Infiltration</i>	170000
Totals	487000 508500

Remaining Capacity – to be allocated

To address future water quality/public health related issues and to support efforts presented in the Watershed Implementation Plan, 40,500 gallons per day of wastewater treatment plant capacity has been allocated to future flows. To address the water quality/public health related issues associated with small lots having high groundwater issues and poorly draining soils, the County will review ways to extend public sewer to these lots. In addition, the County will also review ways to extend sewer to villages designated as Tier III B areas. As the County completes the planning of future sewer extension, amendments to this Allocation Program will be made by amending the County Comprehensive Water and Sewerage Plan. In these future amendments to the County Comprehensive Water and Sewerage Plan, the County will identify the number to equivalent dwelling units (EDUs) to be served, the estimated capacity to be allocated to this area using a flow rate of 125 gallons per day per EDU. In addition, the amendment will report the annual load reduction for Total Nitrogen which can be reported and tracked as part of the Watershed Implementation Plan. After receiving approval from the Maryland Department of the Environment on the adopted amendment to the County Comprehensive Water and Sewerage Plan, the County will complete the necessary design, permitting, funding applications and construction to finalize the extension of sewer.

Table 54. Revised Allocation of Capacity for 660,000 gallons per day

SEWER SERVICE AREA	EXISTING FLOWS	FUTURE FLOWS	RESERVED CAPACITY FOR I&I	TOTAL FLOWS
St. Michaels And Rio Vista	197000 133950	109700 69200	116800	429900 203150
<u>Rio Vista</u>	63050	6400		69450
Bentley Hay	29800	0	0	29800
Unionville, Tunis Mills and Copperville	21100	5900	5400	32400 27000
Royal Oak, Newcomb and Bellevue	47100	68000 17500	21100	105100 64600
Other County Areas	3000	12000	0	15000
Martingham Community	26700 40500	0	(26700)	0 40500
<u>Remaining Capacity – To be Allocated</u>	0	40500		40500
<u>Subtotals</u>	338500	151500		490000
<u>I&I Flow Allocation - Estimated</u>	170000			170000
Totals	324700 508500	192000 151500	143300	660000